

DOCUMENT 00 91 01

ADDENDUM NO. 01
Dated March 10, 2025

1. GENERAL

This document includes requirements that clarify or supersede portions of the bid and/or contract requirements for the project. This Addendum is a Contract Document.

2. SUMMARY

The following changes, additions, and deletions shall be made to the following document(s) in red; all other conditions shall remain the same.

Q&A

1. Question: I received this comment from the BB System Manufacturer "Please note when you use the #10 backboard, PW Athletic insists that you use a thicker diameter basketball post. So we have changed the gooseneck post from the PW #1521G to the PW #1523G. This takes the post from 3 ½ O.D. post to 4 ½ O.D. post." Please clarify change required.

Answer: Correct, the PW #1523G (4 ½" O.D. Post) shall be used.

2. Question: Is 3% DVBE Participation or Good Faith Effort required? (Reference: Notice to Bidders, Item #17.)

Answer: Yes

END OF DOCUMENT